



DIVISION: 04 00 00—MASONRY
Section: 04 71 00—Manufactured Brick Masonry
Section: 04 73 00—Manufactured Stone Masonry

REPORT HOLDER:

WESTLAKE ROYAL STONE LLC

EVALUATION SUBJECT:

DUTCH QUALITY STONE ADHERED VENEER

1.0 EVALUATION SCOPE

1.1 Compliance with the following codes:

- 2021, 2018, 2015 *International Building Code*® (IBC)
- 2021, 2018, 2015 *International Residential Code*® (IRC)
- 2013 *Abu Dhabi International Building Code* (ADIBC)†

†The ADIBC is based on the 2009 IBC. 2009 IBC code sections referenced in this report are the same sections in the ADIBC.

- Other codes (see Section 8.0)

Properties evaluated:

- Veneer strength and durability
- Thermal resistance

1.2 Evaluation to the following green code(s) and/or standards:

- 2022 California Green Building Standards Code (CALGreen), Title 24, Part 11
- 2020, 2015, 2012 and 2008 ICC 700 *National Green Building Standard*™ (ICC 700-2020, ICC 700-2015, ICC 700-2012 and ICC 700-2008)

Attributes verified:

- See Section 3.0

2.0 USES

Dutch Quality Stone Adhered Veneer is used as an adhered, nonload-bearing, exterior veneer on wood-framed or light gage steel stud walls, concrete walls or masonry walls.

3.0 DESCRIPTION

The veneer is a precast concrete product made to resemble natural stone in color and in texture and complies with ASTM C1670 as indicated in 2021 and 2018 IBC Section 2103.1 and 2021 and 2018 IRC Section R606.2.6. The concrete is composed of cement, aggregate, water, admixtures and coloring. The veneer units are molded and cured at the plant. The average saturated weight of the

installed veneer units does not exceed 15 pounds per square foot (73.2 kg/m²). Recognized styles and accessories are as follows:

Styles	Drystack, Fieldstone, Ledge, Tuscan Ridge, Weathered Plank 4, Weathered Plank 6
Accessories	Row Locks 4x5, Row Locks 5.7, Half Brick, Full Brick, Flat Window Trim, Jack Arch Wings, Receptacle Block, Light Block, Water Hydrant, Circle Vent, Arch Top Vent, Address Block

The stone veneer has an R-value of 0.42 when tested in accordance with ASTM C177 at a thickness of 1.5 inches (38 mm).

The attributes of the stone veneer have been verified as conforming to the provisions of (i) CALGreen Section A4.405.1.3 for prefinished building materials and Section A5.406.1.2 for reduced maintenance; (ii) ICC 700-2020 Sections, ICC 700-2015 and ICC 700-2012 Sections 602.1.6 and 11.602.1.6 for termite-resistant materials; (iii) ICC 700-2020 Sections 601.7 and 11.601.7 and ICC 700-2015 and ICC 700-2012 Sections 601.7, 11.601.7, and 12.1(A).601.7 for site-applied finishing materials; and (iv) ICC 700-2008 Section 602.8 for termite-resistant materials and Section 601.7 for site-applied finishing materials. Note that decisions on compliance for those areas rest with the user of this report. The user is advised of the project-specific provisions that may be contingent upon meeting specific conditions, and the verification of those conditions is outside the scope of this report. These codes or standards often provide supplemental information as guidance.

4.0 INSTALLATION

4.1 General:

Installation of the veneer must comply with this report, the manufacturer’s published installation instructions, and the applicable code. The manufacturer’s published installation instructions must be available at the jobsite at all times during installation. In accordance with the code, the veneer can be installed over a lath and mortar scratch coat or directly to concrete and masonry.

4.2 Installation over a Lath and Mortar Scratch Coat Over Framed Walls:

The scratch coat must be installed over a water-resistive barrier complying with 2021 and 2018 IBC Section 1404.10.1.1 (2015 IBC Section 1405.10.1.1) or IRC Section R703.12.3, as applicable. Also, flashing must be installed as

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

required by 2021 and 2018 IBC Section 1404.10.1.2 (2015 IBC Section 1405.10.1.2) or IRC Sections R703.4 and R703.12.2, as applicable, including a foundation weep screed installed at the bottom of the stone veneer. The foundation weep screed must comply with, and be installed in accordance with, the requirements for flashing at foundation shown in 2021 and 2018 IBC Section 1404.10.1.2.1 (2015 IBC Section 1405.10.1.2.1) or IRC Section R703.12.2, as applicable. The veneer must be installed with the clearances required by 2021 and 2018 IBC Section 1404.10.1.3 (2015 IBC Section 1405.10.1.3) or IRC Section R703.12.1, as applicable.

Lathing must comply with IBC Section 2510 [referenced from 2021 and 2018 IBC Section 1404.10.1.4.1 (2015 IBC Section 1405.10.1.4.1) or IRC Section R703.7.1 (referenced from IRC Section R703.12)]. The scratch coat must be applied in accordance with 2021 and 2018 IBC Section 1404.10.1.4.2 (2015 IBC Section 1405.10.1.4.2) and the veneer units must be adhered to the scratch coat in accordance with 2021 and 2018 IBC Section 1404.10.1.4.3 (2015 IBC Section 1405.10.1.4.3). The mortar used to adhere the veneer units to the scratch coat must comply with IBC Section 2103.2.4.

4.3 Installation over Concrete and Masonry:

Installation over concrete and masonry must comply with 2021 and 2018 IBC Section 1404.10.1.5 (2015 IBC Section 1405.10.1.5). When adhering the veneer units directly to the concrete or masonry, the supporting surfaces must be prepared in accordance with IBC Section 2510.7, and the veneer units must be adhered to the supporting surface as described in Section 4.2. When adhering the veneer units to a lath and mortar scratch coat, the lathing and scratch coat preparation must comply with Section 4.2.

5.0 CONDITIONS OF USE

The Dutch Quality Stone adhered veneer described in this report complies with, or is a suitable alternative to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 Installation must comply with this report, the manufacturer's published installation instructions and the applicable code. In the event of a conflict between the manufacturer's published installation instructions and this report, this report governs.
- 5.2 Expansion or control joints used to limit the effect of differential movement of supports are to be specified by the architect, designer or veneer manufacturer, in that order. Consideration must also be given to movement caused by temperature change, shrinkage, creep and deflection.
- 5.3 In jurisdictions adopting the IBC, the supporting wall framing must be designed to support the installed weight of the veneer system, including stone veneer, scratch coat and setting bed, as applicable. At wall

openings, the supporting members must be designed to limit deflection to $1/600$ of the span of the supporting members. In jurisdictions adopting the IRC, where the seismic provisions of Section R301.2.2 apply, the average weight of the wall supporting the precast stone veneer, including the weight of the veneer system, must be determined. When this weight exceeds the applicable limits of 2021 and 2018 IRC Section R301.2.2.2 (2015 IRC Section R301.2.2.2.1), an engineered design of the wall construction must be performed in accordance with IRC Section R301.1.3.

- 5.4 Dutch Quality Stone Adhered Veneer is manufactured under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

- 6.1 Data in accordance with the ICC-ES Acceptance Criteria for Adhered Manufactured Stone Masonry Veneer (AC51), dated June 2018 (Editorially revised January 2021).
- 6.2 Report of testing in accordance with ASTM C177.

7.0 IDENTIFICATION

- 7.1 Each package of veneer is identified with the manufacturer's name (Westlake Royal Stone), the brand name (Dutch Quality Stone), the product name, style name and the evaluation report number (ESR-1942).
- 7.2 The report holder's contact information is the following:

WESTLAKE ROYAL STONE LLC
2801 POST OAK BOULEVARD, SUITE 600
HOUSTON, TEXAS 77056
(855)769-2585
www.royalbuildingproducts.com/boral

8.0 OTHER CODES

8.1 Evaluation Scope:

In addition to the codes referenced in Section 1.0, the products described in this report were evaluated for compliance with the following codes:

- 2012, 2009 and 2006 *International Building Code*® (IBC)
- 2012, 2009 and 2006 *International Residential Code*® (IRC)

The Dutch Quality Stone products addressed in Sections 2.0 through 7.0 of this report comply with, or are suitable alternatives to what is specified in, the codes listed above, and must be installed in accordance with the 2021, 2018, and 2015 IBC and IRC, as described in Section 4.0.